**M/s. A. NAYAK**
H.T. ELECTRICAL, CIVIL & MECHANICAL CONTRACTOR
L.C. NO. 1539 (H.T)
Sale Tax No - 3800991 Service Tax No - ADMPN2421KST001

OFFICE ADDRESS
Samalpur, Balia
Balasore
Ph: 06782 - 261933
Mob: 9338466665

Ref. No. :.....  Date :.....

Date: 4/3/2016

To

The Managing Director,
Odisha Knowledge Corporation Ltd.,
Bhubaneswar.

**Subject: Verification report of ICT lab**

Dear Sir,

We are a registered contractor << AMALENDU NAYAK >>, an approved Electrical contractor of Government of Odisha, bearing Licence No. <<1539 >> (Copy of license is enclosed) for your kind perusal.

After verification of the following items of the ICT lab at <<U.N.HIGH SCHOOL>>, <<21080100503>>,<<BAHANAGA >>,<<BALASORE>> as per the minimum specification mentioned below, the report for the same is being attached.

**M/s. A. NAYAK**
H.T. ELECTRICAL, CIVIL & MECHANICAL CONTRACTOR
L.C. NO. 1539 (H.T)
Sale Tax No - 3800991 Service Tax No - ADMPN2421KST001

OFFICE ADDRESS
Samalpur, Balia
Balasore
Ph: 06782 - 261933
Mob: 9338466665

Ref. No. :.....  Date : .....

| Sr. No. | Item name | Minimum Specifications | Quantity | Actual |
|---|---|---|---|---|
| 1 | Earthing (as per IS specifications) | Copper plate earthing stations making earthing with copper earth plate | 1 | 1 OK |
| | | 600 mm x 600 mm x 3 mm thick including funnel, charcoal/coke, salt, all earth work. | | 1 |
| 2 | Switches and sockets (ISI Mark) | 5 A- 240 V switches | 15 | 15 |
| | | 2 in 1 5A and 15A Sockets | 15 | 15 |
| | | 15 A – 240 V socket with shutter | 2 | 2 |
| | | Indicative Brands: - Anchor / Havells / crabtree /Wipro /Phillips / Legrand (Pls. tick) Switches and sockets is to be provided for all electronics/IT equipment including printer and Projection System to be placed at lab technician table. | | Anchor Switches |
| 3 | Wiring (ISI Mark) | PVC conduits including MS/GI boxes. All wires should be covered, insulated and properly clamped. Wiring for 5 and 15A power outlets with 4 square mm PVC insulated stranded copper conductor wires Earthing of 3rd pin with PVC insulated green color 2.5 square mm copper wire | Full Lab | Yes |

With regards

Name & Signature with seal

Er. Ananda Nayak
Electrical Contractor
L.C. No-1539 (H.T)