Ref no: 191

Date: 17.09.14

To

The Managing Director,
Odisha Knowledge Corporation Ltd.,
Bhubaneswar.

Subject: Verification report of ICT lab

Dear Sir,

We are a registered contractor Er. R.K. Behera, an approved Electrical contractor of Government of Odisha, bearing Licence No. 2995 (Copy of license is enclosed) for your kind perusal.

After verification of the following items of the ICT lab at DADHIBAMAN JEW BIDYAPIHA ITUA, 21121312802, TANGI , Cuttack as per the minimum specification mentioned below, the report for the same is being attached.

Sr. No.	Item name	Minimum Specifications	Quantity
1	Earthing (as per IS specifications)	Copper plate earthing stations making earthing with copper earth plate	1
		600 mm x 600 mm x 3 mm thick including funnel, charcoal/coke, salt, all earth work.	
2	Switches and sockets (ISI Mark)	5 A- 240 V switches	15
		2 in 1 5A and 15A Sockets	15
		15 A – 240 V socket with shutter	2
		Indicative Brands: - Anchor / Havells / crabtree /Wipro /Phillips / Legrand (Pls. tick) Switches and sockets is to be provided for all electronics/IT equipment including printer and Projection System to be placed at lab technician table.	
3	Wiring (ISI Mark)	PVC conduits including MS/GI boxes. All wires should be covered, insulated and properly clamped. Wiring for 5 and 15A power outlets with 4 square mm PVC insulated stranded copper conductor wires Earthing of 3rd pin with PVC insulated green color 2.5 square mm copper wire	Full Lab

With regards

Keshuv Informatics
Lapamudra Mishra
Proprietor

Name & Signature with seal

Er. R. K. Behera
S.C.C No 2995 (HV)

Encl.

1. Verification report for the given items
2. Electrical contractor's licence copy

FORM C

(Regulation 25)

ELECTRICAL SUPERVISOR'S CERTIFICATE OF COMPETENCY

This certificate is to be renewed for a period of three years at a time and must be produced on demand by the Secy. (Not transferable or renewable by any authority other than the Electrical licensing Board, Orissa).

I do hereby certify that Shri. Rabin Kishore Behera ....., son of. Dasharatha Behera has this day been granted this certificate of competency as an electrical supervisor [illegible] Number 2995(HV) [illegible] of the following

Date of approval by E. L B. O. 11.1.94

DATE OF BIRTH

15-5-67

18.2.94

ALLOWED TO SUPERVISE EXECUTION OF M.V INSTALLATION [illegible] UPTO & INCLUSS[illegible] 650V AS PER THE DEC[illegible] 89th ELBO MEETING HELD ON 11.1.94 UNDER REGULATION 25 IV

18.2.94

Electrical Inspector to Government of Orissa and Secretary Electrical Licensing Board, Orissa

18.2.94