

M/s. DURGA ELECTRICAL*Prop. : Rabindra Patra*

Govt. Electrical Contractor

Registration No. 1643 (H.T.)

Erection of Panel, Tower, Structure, Transformer, Cable Laying,
 Domestic & Industrial, Illumination and Govt. Order Supplier
 2nd Daily Market Road, Jeypore-764001 Dist. Koraput (Odisha)

Ref. No. _____

Date : 28.07.2014

To

The Managing Director,
 Odisha Knowledge Corporation Ltd.,
 Bhubaneswar.

Subject: Verification report of ICT lab

Dear Sir,

We are a registered contractor DURGA ELECTRICALS, an approved Electrical contractor of Government of Odisha, bearing Licence No. 1643 (Copy of license is enclosed) for your kind perusal.

After verification of the following items of the ICT lab at Govt. High School, Nighamaniguda<<21290608403>>,Block- Koraput, Dist-Koraput as per the minimum specification mentioned below, the report for the same is being attached.

Sr. No.	Item name	Minimum Specifications	Quantity	REMARK
1	Earthing (as per IS specifications)	Copper plate earthing stations making earthing with copper earth plate	1	1. No earthing chamber 2. Earthing wire(copper) is to reach the main board
		600 mm x 600 mm x 3 mm thick including funnel, charcoal/coke, salt, all earth work.		Less amount of charcoal and salt used • Earthing not as per specifications.
2	Switches and sockets (ISI Mark)	5 A- 240 V switches	15	Ok (17 no.s)
		2 in 1 5A and 15A Sockets	15	Ok (17 no.s)
		15 A – 240 V socket with shutter	2	1

Rabindra Patra
M/s. DURGA ELECTRICAL
 Prop. Rabindra Patra
 Govt. Electrical Contractor
 Regd. No. 1643 - (HT)
 Dt. 27.12.05

		Indicative Brands: - Anchor / Havells / crabtree / Wipro / Phillips / Legrand (Pls. tick) Switches and sockets is to be provided for all electronics/IT equipment including printer and Projection System to be placed at lab technician table.		Anchor OK
3	Wiring (ISI Mark)	PVC conduits including MS/GI boxes. All wires should be covered, insulated and properly clamped. Wiring for 5 and 15A power outlets with 4 square mm PVC insulated stranded copper conductor wires Earthing of 3rd pin with PVC insulated green color 2.5 square mm copper wire	Full Lab	Main board is not a make of GI/MS. Wood and PVC boxes, covered and clamped properly.

With regards


Rabindra Patra

(Govt. Electrical Contractor)

M/s. DURGA ELECTRICAL
Prop. Rabindra Patra
Govt. Electrical Contractor
Regd. No. 1643 - (HT)
Dt. 27.12.05

Encl.

1. Verification report for the given items
2. Electrical contractor's licence copy