

To

The Managing Director,
Odisha Knowledge Corporation Ltd,
Bhubaneswar.
Subject: Verification report of ICT lab

Dear Sir,

We are a registered contractor RAMESH PALAI an approved Electrician workman of Government of Odisha, bearing License No. BSOAQR027 (Copy of license is enclosed) for your kind perusal.

After verification of the following items of the ICT lab at **SADAPANOUSAN HIGH SCHOOL, 21160500102 NAYAGARH**, Nayagarh as per the minimum specification mentioned below, the report for the same is being attached.

Sr. No.	Item name	Minimum Specifications	Quantity	Remarks
1	Earthing (as per IS specifications)	Copper plate earthing stations making earthing with copper earth plate	1	OK
		600 mm x 600 mm x 3 mm thick including funnel, charcoal/coke sat. at each work.		Not ok
2	Switches and sockets (IS Mark)	5 A - 240 V switches	15	14
		2 of 1 15A and 13A Sockets	15	18
		15 A - 240 V socket with shutter	2	1
		Inclusive Brands - Anchor / Havells / Crestite / Wipro / Philips / Legrand (Ph. box)		ANCHOR, All ok
	Switches and sockets is to be provided for all electronics/IT equipment including printer and Projection System to be placed at lab technician table			
3	Wiring (IS Mark)	PVC conduits including MS/GI boxes. All wires should be covered, insulated and properly clamped.	Full (00)	Wiring for 5 and 15A power outlets with 2.5 square mm PVC (KALINGA) insulated standard copper conductor wire.
		Wiring for 5 and 15A power outlets with 4 square mm PVC insulated stranded copper conductor wire. Earthing of 3rd pin with PVC insulated green color 2.5 square mm copper wire.		Earthing of 3rd pin with PVC insulated KALINGA GREEN color 1.5 square mm copper wire.

Ramesh Chandra Palai
With regards

Name & Signature with seal
Ramesh Chandra Palai
Electrician Workman Odisha
U. No - BSO-NGR027/

Enc:

1. Verification report for the given items
2. Electrical contractor's license copy



Prateep Kumar Mohanty

FORM - F
(Regulation 21)

ELECTRICAL WORKMAN'S PERMIT

This permit is to renewed for a period of five years at a time and must be produced on demand by the Electrical Inspector.

(Not transferable or renewable by any authority other than the Electrical Licensing Board, Orissa)

Name and Address of the holder

Ramesh Palai

Date of issue of permit

25-6-2009

Category of permit

W.C

Workman-C (Lineman) (O.H. & U.G.) installations including equipments upto 650 Volts

Date of approval by the E.L.B.O.

Approved in _____ Center in the examination held on _____

Registration No

1861 N/111 - 817

approved in the _____ compelling of E.L.B.O. held on _____

Date of Birth

21-06-1968

(1968 June 19 Birthday)

Electrical Inspector to
Electrical Licensing Board (T&O)
Bhubaneswar