Ref no: DLC\NGR\023\14

Date: 19/06/14

To

The Managing Director,
Odisha Knowledge Corporation Ltd.,
Bhubaneswar.
Subject: Verification report of ICT lab

Dear Sir,

We are a registered contractor RAMESH PALAI an approved Electrician workman of Government

of Odisha, bearing Licence No. BBS\NGH\827 (Copy of license is enclosed) for your kind perusal.

After verification of the following items of the ICT lab at JANATA BIDYAPITHA, Baunsiyapada, 21160501506, Nayagarh, Nayagarh as per the minimum specification mentioned below, the report for the same is being attached.

Sr. No.	*Item name*	*Minimum Specifications*	*Quantity*	*Remarks*
1	Earthing (as per IS specifications)	Copper plate earthing stations making earthing with copper earth plate	1	8 Ω
		600 mm x 600 mm x 3 mm thick including funnel, charcoal/coke, salt, all earth work.		Not ok
2	Switches and sockets (ISI Mark)	5 A- 240 V switches	15	14
		2 in 1 5A and 15A Sockets	15	18
		15 A – 240 V socket with shutter	2	1
		Indicative Brands: - Anchor / Havells / crabtree /Wipro /Phillips / Legrand (Pls. tick) Switches and sockets is to be provided for all electronics/IT equipment including printer and Projection System to be placed at lab technician table.		Anchor, All ok
3	Wiring (ISI Mark)	PVC conduits including MS/GI boxes. All wires should be covered, insulated and properly clamped. Wiring for 5 and 15A power outlets with 4 square mm PVC insulated stranded copper conductor wires Earthing of 3rd pin with PVC insulated green color 2.5 square mm copper wire	Full Lab	Wiring for 5 and 15A power outlets with 2.5 square mm PVC(KALINGA) insulated stranded copper conductor wires Earthling of 3rd pin with PVC insulated KALINGA GREEN color 1.5 square mm copper wire

Ramesh Chandra Palai

With regards

~~Name~~ & Signature with seal

Ramesh Chandra Palai
Electrician Workman Odagaon
Li . No - BBS/NGR/827

Encl.

1. Verification report for the given items
2. Electrical contractor's licence copy

ORICOM EDUCATION ODAGAON

Pratap Kumar Mohanty

FORM - F
(Regulation 21)

ELECTRICAL WORKMAN'S PERMIT

This permit is to renewed for a period of five years at a time and must be prodcued on demand by the Electrical Inspector.

(Not transferable or renewable by any authority other than the Electrical Licensing Board, Orissa)

Name and Address of the holder Ramesh Pala

Date of issue of permit 26.6.2009

Category of permit Man-C Workman-C (Lineman) (O.H. & U.G.) installations including equipments upto 650 Volts

Date of approval by the E.L.B.O. Appeared in Bhadrak Center in the examination held on 2008 approved in the 127th meeting of E.L.B.O. held on 19/4/09

Registration No. ROW/NGHT-827

Date of Birth 21.06.1968

(Age 41 Years 19 Days)

Electrical Inspector to 26/6/09
Electrical Inspector (T&D)
Bhubaneswar