

To

The Managing Director,  
Odisha Knowledge Corporation Ltd,  
Bhubaneswar.  
Subject: Verification report of ICT lab

Dear Sir,

We are a registered contractor RAMCHANDRA PALAI (an approved Electrician workman of Government) of Odisha, bearing License No. BSSONGR027 (Copy of license is enclosed) for your kind perusal.

After verification of the following items of the ICT lab at **N.K.HIGH SCHOOL 21160507502 NATAGARH**, Nayagarh as per the minimum specifications mentioned below, the report for the same is being attached.

Sr. No.	Item name	Minimum Specifications	Quantity	Remarks
1	Earthing (as per ISI specifications)	Copper plate earthing stations making earthing with copper earth plate	1	OK
		600 mm x 600 mm x 3 mm thick including funnel, charcoal/coke, salt, all each work.		Not ok
2	Switches and sockets (ISI Mark)	2 A - 240 V switches	15	14
		2 of 1 1A and 15A Sockets	15	18
		15 A - 240 V socket with shutter	2	1
		Indicative Brands - Anchor / Havells / crastee / Wipro / Philips / Legrand (Pls. tick)		ANCHOR, All ok
	Switches and sockets is to be provided for all electronics/IT equipment including printer and Projection System to be placed at lab technician table.			
3	Wiring (ISI Mark)	PVC conduits including MS/GI boxes. All wires should be covered, insulated and properly clamped.	Full (00)	Wiring for 5 and 15A power outlets with 2.5 square mm PVC (KALINGA) insulated standard copper conductor wire.
		Wiring for 3 and 15A power outlets with 4 square mm PVC insulated standard copper conductor wire.		Earthing of 3rd pin with PVC insulated KALINGA GREEN color 1.5 square mm copper wire.

*Ramesh Chandra Palai*  
With regards

Name & Signature with seal  
**Ramesh Chandra Palai**  
Electrician Workman Odisha  
U. No - BSSONGR027/

Enc:

1. Verification report for the given items
2. Electrical contractor's license copy



*Prateek Kumar Mohanty*

FORM - F  
(Regulation 21)

ELECTRICAL WORKMAN'S PERMIT

This permit is to renewed for a period of five years at a time and must be produced on demand by the Electrical Inspector.

(Not transferable or renewable by any authority other than the Electrical Licensing Board, Orissa)

Name and Address of the holder

Ramesh Palai

Date of issue of permit

25-6-2009

Category of permit

W.C

Workman-C (Lineman) (O.H. & U.G.) installations including equipments upto 650 Volts

Date of approval by the E.L.B.O.

Approved in \_\_\_\_\_ Center in the examination held on \_\_\_\_\_

Registration No

1861 N/111 - 817

approved in the \_\_\_\_\_ compelling of E.L.B.O. held on \_\_\_\_\_

Date of Birth

21-06-1968

(1968 June 19 Birthday)

Electrical Inspector to  
Electrical Licensing Board (T&O)

Bhubaneswar