

Ref no:

Date:

To

The Managing Director,
Odisha Knowledge Corporation Ltd.,
Bhubaneswar.

Subject: Verification report of ICT lab

Dear Sir,

We are a registered contractor Mr. Girdhar Agrawal, an approved Electrical contractor of Government of Odisha, bearing License No. 872(HT) (Copy of license is enclosed) for your kind perusal.

After verification of the following items of the ICT lab

All GOVT U.G. HIGH SCHOOL, CHANDALI DUNGURIPALI

UDISE Code: 21230310901 District: Subarnapur as per the minimum specification mentioned below, the report for the same is being attached.

Sr. No.	Item name	Minimum Specifications	Quantity
1	Earthing (as per IS specifications)	Copper plate earthing stations making earthing with copper earth rods 600 mm x 600 mm x 3 mm thick including fence, charpoohole, well, RT earth work	Not Visited 1 nos. earthing G.I. p. 30 ft. 1/2"
	5 A - 240 V switches	14	
	2 In 1 5A and 15A Sockets	12	
	10 A - 240 V socket with shutter	1	
2	Switches and sockets (ISI Mark)	Indicative Brands: - Anchor / Havells / crdne / MPN / Philips / Legend (Pis. 30k) Switches and sockets is to be provided for all electrical equipment including printer and Projection System to be placed at lab technician table.	Anchor 14 Havells .. Crdne .. Wires .. Philips .. Legend ..
3	Wiring (ISI Mark)	PVC conduits including MG/GI boxes. All wires should be covered, insulated and properly clamped. Wiring for 5 and 15A power outlets with 4 square mm PVC insulated stranded copper conductor wires Earthing of 3rd pin with PVC insulated green color 2.5 square mm copper wire	available Kalinga tools 2.5 mm ² 1.5 m. long 1.5 mm ² properly drawn

End.

Electrical contractor's source copy



With regards

Giridhar Agrawal
Name & Signature with Seal
G.L. AGRAWAL
COLLECTOR STMT
VISTED ON 28.03.2014